Series 681

Pressure reducing valves made of gunmetal with threaded connections

681



C € [Ħ[🞰 🎡 WRAS

MATERIAL



SPECIFICATION



1/2" - 2"



Inlet pressure: -20°C to + 120°C up to 40 bar Outlet pressure:

0.5 to 15 bar depending on version

SUITABLE FOR

Liquids	neutral and non-neutral	<u>الم</u>
Air, gases and vapours	neutral and non-neutral	\ge
Potable water cold	up to 40°C	
Potable water hot	up to 95°C	

EXAMPLES OF USE

For the protection of:

- domestic water supply systems

- commercial and industrial plants

against too high supply pressure.

Pressure reducers are used, if within a piping system despite of varying pressures on the inlet side a certain pressure must not be exceeded on the outlet side.

- potable water supply according to DIN 1988
- process water supply in industrial-and building technology
- snow-making equipment
- fire-fighting equipment and sprinkler systems
- shipbuilding industry and offshore plants

APPROVALS

DIN-DVGW type examination (up to 80°C)

Type approval ACS

Classification society

Type approval WRAS (up to 85°C)

Type approval PZH

TR ZU 032/2013 - TR ZU 010/2011

Type approval ÜA (R-15.2.4-21-17231 Land Salzburg)

Requirements

DIN DVGW guidelines DIN EN ISO 3822 DIN EN 1567 DGR 2014/68/EU DIN 1988

DNV Lloyd's Register EMEA American Bureau of Shipping Bureau Veritas Russian Maritime Register of Shipping Registro Italiano Navale

DNV LR EMEA ABS ΒV RMRS RINA

MATERIALS

Component	Material	DIN EN	ASME
Inlet body	Gunmetal	СС499К	СС499К
Outlet body	Gunmetal	СС499К	СС499К
Internal parts	Gunmetal	СС499К	CC499K
	Stainless Steel	1.4404	316 L
Spring	Spring steel with anti-rust protection	1.1200	ASTM A228
Strainer	Stainless Steel	1.4404	316 L



m	with diaphragm	High-quality, heat-resistant moulded elastomere, fabric-reinforced diaphragm. Adjustment by means of non-rising spindle. Insert with balanced single seat valve made of gunmetal.
Complete valv	e insert SP/HP (order code: 681 Inser	t-DNseal) available as replacement part can be exchanged without removing the valve.
Complete valv	e insert LP (order code: 681 LP Insert	-DNseal) available as replacement part can be exchanged without removing the valve.
Built-in dirt tra	ap made of stainless steel.	
Mesh size:	DN 15 to DN 32 0,60 mm DN 40 and DN 50 0,75 mm	
■ MEDIUM		
GF	gaseous and liquid	for water, neutral and non-sticking liquids, compressed air and neutral gases; optionally wit FPM elastomere seals for non-neutral media i.e. oils, fuels, oil-laden compressed air, etc. No suitable with steam.

TYPE OF LIFTIN	G MECHANISM
0	without lifting device

	RESSURE RANGES		
SP	Standard version	Inlet pressure: up to 40 bar	Outlet pressure: from 1 to 8 bar
HP	High-pressure version	Inlet pressure: up to 40 bar	Outlet pressure: from 5 to 15 bar
LP	Low-pressure version	Inlet pressure: up to 25 bar	Outlet pressure: from 0,5 to 2 bar

AVAILABLE NOMI						
Nominal diameter DN	15	20	25	32	40	50
Inlet	1/2" (15)	3/4" (20)	1" (25)	1 1/4" (32)	1 1/2" (40)	2" (50)
Outlet	1/2" (15)	3/4" (20)	1" (25)	1 1/4" (32)	1 1/2" (40)	2" (50)

	CTION INLET / OUTLET THREAD		
BSP-Tm / BSP-Tm	Standard threaded connections	Male thread BSP-T / Male thread BSP-T	DIN EN 10226, ISO 7-1 / DIN EN 10226, ISO 7-1
f/f	Version with female thread available in sizes DN15, DN20 and	Female thread BSP-P / Female thread BSP-P DN25	DIN EN ISO 228-1 / DIN EN ISO 228-1
NPT-f / NPT-f	Version with female thread available in sizes DN15, DN20 and	Female thread NPT-f / Female thread NPT-f	ANSI B1.20.1 / ANSI B1.20.1

SEALS			
EPDM	Ethylene propylene diene	Elastomere moulded diaphragm and seals approvals according to drinking water directive	–20°C to +120°C (up to 8 bar outlet pressure) –20°C to +95°C (from 8 bar outlet pressure)
FKM	Fluorocarbon	Elastomere moulded diaphragm and seals	–10°C to +120°C (up to 8 bar outlet pressure) –10°C to +95°C (from 8 bar outlet pressure)




■ NOMINAL DIAMETERS, CONNECTIONS, INSTALLATION DIMENSIONS

Series 681: Connection, install	ation dimens	ions, ranges of a	idjustment				
Connection	DN	15	20	25	32	40	50
Inlet DIN EN 10226	G1	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"
Dutlet DIN EN 10226	G2	1/2"	3/4"	1"			
nlet pressure SP, HP up to	bar	40	40	40	40	40	40
nlet pressure LP up to	bar	25	25	25	25	25	25
)utlet pressure	bar	0,5 - 2	0,5 - 2	0,5 - 2	0,5 - 2	0,5 - 2	0,5 - 2
		1 - 8	1 - 8	1 - 8	1 - 8	1 - 8	1 - 8
		5 - 15	5 - 15	5 - 15	5 - 15	5 - 15	5 - 15
nstallation dimensions	L	142	158	180	193	226	252
n mm	1	80	90	100	105	130	140
	1	85	95	105			
	H (H1)	102 (128 ¹)	102 (128 ¹)	130 (150 ¹)	130 (150 ¹)	165 (185 ¹)	165 (185 ¹)
	H2 (H3)	124 (150 ²)	124(150 ²)	161 (181 ²)	161 (181 ²)	198 (218 ²)	198 (218²)
	h	33	33	45	45	70	70
	SW1	30	37	46	52	65	75
	SW2	28	35	43			
Pressure gauge connection Dutlet pressure	G3	1/4" axial					
Neight	kg	1,2 (1,5 ¹)	1,3 (1,6 ¹)	2,4 (2,9 ¹)	2,6 (3,1 ¹)	5,5 (6,2 ¹)	6,0 (6,7 ¹)
Coefficient of flow K _{vs} ³	m³/h	3	3,5	6,7	7,6	12,5	15

¹for type 681mGFO-LP ²for type 681mGFO-LP S15 ³The K_{vs} value was determined according to DIN EN 60534-2-3. Instructions on how to determine size and capacity are to be found under section 2.

■ MAIN DIMENSIONS, INSTALLATION DIMENSIONS






	Valve version	Medium	Lifting device	Outlet pressure	Nominal diameter DN	Connec Inlet	tion type Outlet	Connec Inlet	tion size Outlet	Seal	Options	Optional: fixed setting	Qua tity
681	m	GF	0	SP	20	BSP-T m	BSP-T m	20	20	EPDM	Manometer 36		8
681	m	GF	0	SP	15	f	f	15	15	EPDM			4
681	m	GF	0										
681	m	GF	0										
PRO	PERTIES												
S15	Hand wheel	(plastic) for t	ool-free se	tting of setpre	essure ¹								
S17	Supply with n	nanometers s	suitable for t	he valve finish	1								
S71	Preliminary s preset pressu		ection again	st manipulatio	n of the								
or nomir	al diameters DN	N15 to DN50 ou	utlet pressur	e ranges LP and	I SP								
	ONS												
GOX	of specific m production p	aterials inclu rocess	uding oil- ar	ns by employn 1d grease free ure max. 60°C			P03	Galvanically	v nickel-plate	ed finish			
P01	Oil- and grea	se-free produ	uction				FE :	Setting and	sealing				Ľ
	01 . 11 .												_
P02	Chemically hi	ickel-plated f	inish										
	Chemically hi							Sealing mat	erial				
CER	FIFICATES / A	APPROVALS	5	4 2.2 (WKZ 2.	2)		C05				SP 3, 3-A,), ficate:		
CERT	FIFICATES / A	APPROVALS	5 DIN EN 1020		2)		C05	Manufactur Please indic	er certificati	ion of certi	ficate:		
CER C01 C02	FIFICATES / A Factory certi Test certifica	APPROVALS ificate acc. D te acc. DIN E certificate ac	5)IN EN 1020 N 10204 3.1				C05 C06	Manufactur Please indic ATEX evalua	er certificati ate descript	ion of certil 2014/34/EU	ficate:		
	FIFICATES / A Factory certi Test certifica Material test (pressure ret	APPROVALS ificate acc. D te acc. DIN E certificate ac aining part) ndividual insp	5 DIN EN 1020 N 10204 3.1 CC. DIN EN 1	(WPZ 3.1)			C05 C06 C10	Manufactur Please indic ATEX evalua Certificate c Certification	er certificati ate descript ation acc. to of oil- and gr of the produ	ion of certif 2014/34/EU rease free p uction proc	ficate:		
CO1 CO2 CO3 CO4	FIFICATES / A Factory certi Test certifica Material test (pressure ret TÜV/DEKRA i (TÜV/DEKRA-	APPROVALS ificate acc. D te acc. DIN E certificate ac aining part) ndividual ins APZ)	S NIN EN 1020 N 10204 3.1 cc. DIN EN 1 pection acc	(WPZ 3.1) 10204 3.1 (MPZ			C05 C06 C10	Manufactur Please indic ATEX evalua Certificate c Certification	er certificati ate descript ation acc. to of oil- and gr of the produ	ion of certif 2014/34/EU rease free p uction proc	ficate: J production ess especially		
CO1 CO2 CO3 CO4	FIFICATES / A Factory certi Test certifica Material test (pressure ret TÜV/DEKRA i (TÜV/DEKRA- ISSIONS / A	APPROVALS ificate acc. D te acc. DIN E certificate ac aining part) ndividual insp -APZ) CCREDITAT	S DIN EN 1020 N 10204 3.1 cc. DIN EN 1 pection acc	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2	Z 3.1)		C05 C06 C10 C11	Manufactur Please indic ATEX evalua Certificate o Certification ous oxygen	er certificati ation acc. to of oil- and gr of the produ applications	ion of certil 2014/34/EL ease free p uction proc by employ	ficate: J production ess especially ment of specif		
CO1 CO2 CO3 CO4	FIFICATES / A Factory certi Test certifica Material test (pressure ret TÜV/DEKRA i (TÜV/DEKRA i (TÜV/DEKRA i (TÜV/DEKRA i EC Type exar EAC - certific	APPROVALS ificate acc. D te acc. DIN E certificate ac aining part) ndividual insp -APZ) CCREDITAT mination acc cate/declara	S DIN EN 1020 N 10204 3.1 Dection acc DIN EN 1 Dection acc TIONS . to Directiv tion with pa	(WPZ 3.1) 10204 3.1 (MPZ	Z 3.1)		C05 C06 C10 C11 AK1	Manufactur Please indic ATEX evalua Certificate o Certification ous oxygen Det Norske	er certificati ate descript ation acc. to of oil- and gr of the produ	ion of certil 2014/34/EL ease free p uction proc by employ IV) type ap	ficate: J production ess especially ment of specif		
 CER C01 C02 C03 C04 ADM AA1 	FIFICATES / A Factory certi Test certifica Material test (pressure ret TÜV/DEKRA i (TÜV/DEKRA i (TÜV/DEKRA)	APPROVALS ificate acc. D te acc. DIN E certificate ac aining part) ndividual insp -APZ) CCREDITAT nination acc cate/declara rking of the v erein des Ga:	S NIN EN 1020 N 10204 3.1 cc. DIN EN 1 pection acc NONS . to Directiv tion with pa /alve	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 re 2014/68/EU	2 3.1) 2 valve		C05 C06 C10 C11 AK1 AK2	Manufactur Please indic ATEX evalua Certificate o Certification ous oxygen Det Norske Lloyd's Reg	er certificati ation acc. to of oil- and gr of the produ applications Veritas (DN jister (LR) ty	ion of certil 2014/34/EU rease free p uction proc by employ IV) type ap	ficate: J production ess especially ment of specif	ic materials	
 CER C01 C02 C03 C04 ADM AA1 AA4 	FIFICATES / A Factory certificat Test certificat Material test (pressure ret TÜV/DEKRA i (TÜV/DEKRA i (TÜV/DEKRA i EC Type exar EAC - certific and laser ma Deutscher Ve type approve	APPROVALS ificate acc. D te acc. DIN E certificate ac aining part) ndividual insp -APZ) CCREDITAT mination acc cate/declara rking of the v erein des Gas	S DIN EN 1020 N 10204 3.1 cc. DIN EN 1 pection acc IONS . to Directiv tion with pa /alve s- und Was	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 re 2014/68/EU assport for the	Z 3.1) 9 valve 7GW		C05 C06 C10 C11 AK1 AK2 AK3	Manufactur Please indic ATEX evalua Certificate o Certification ous oxygen Det Norske Lloyd's Reg American E	er certificati ation acc. to of oil- and gr of the produ applications Veritas (DN jister (LR) ty	ion of certil 2014/34/EL ease free p uction proc by employ IV) type ap vpe approv hipping (AE	ficate: J production ess especially ment of specif oproval al 3S) type appr	ic materials	
 CER C01 C02 C03 C04 AA1 AA1 AA4 AB1 AB2 	FIFICATES / A Factory certificat Test certificat Material test (pressure ret TÜV/DEKRA i (TÜV/DEKRA i (TÜV/DEKRA i (TÜV/DEKRA i (TÜV/DEKRA i CUV/DEKRA i (TÜV/DEKRA i) (TÜV/DEKRA i (TÜV/DEKRA i) (TÜV/DEKRA i (TÜV/DEKRA i) (TÜV/DEKRA i) (TÜ	APPROVALS ificate acc. D te acc. DIN E certificate ac aining part) ndividual insp -APZ) CCREDITAT mination acc cate/declara rking of the v erein des Gas al ations and ad	S DIN EN 1020 N 10204 3.1 cc. DIN EN 1 pection acc TIONS . to Directiv tion with pa valve s- und Was	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 re 2014/68/EU assport for the serfaches, DV	2 3.1) 9 valve 7GW pe		C05 C06 C10 C11 AK1 AK2 AK3 AK4	Manufactur Please indic ATEX evalua Certificate o Certification ous oxygen Det Norske Lloyd's Reg American E Bureau Ver	er certificati ate descript ation acc. to of oil- and gr of the produ applications Veritas (DN jister (LR) ty Bureau of SH itas (BV) ty aritime Regi	ion of certil 2014/34/EL ease free p uction proc by employ IV) type ap /pe approv hipping (AE pe approva	ficate: J production ess especially ment of specif oproval al 3S) type appr	oval	
 CER C01 C02 C03 C04 AA1 AA1 AA4 AB1 	FIFICATES / A Factory certificat Test certificat Material test (pressure ret TÜV/DEKRA i (TÜV/DEKRA i (TÜV/DEKRA i EC Type exar EAC - certific and laser ma Deutscher Vi type approva Water regula approval	APPROVALS ificate acc. D te acc. DIN E certificate ac aining part) ndividual insp -APZ) CCREDITAT mination acc cate/declara rking of the v erein des Gas al ations and ad de Conformit r industriell c	S DIN EN 1020 N 10204 3.1 CC. DIN EN 1 Dection acc CIONS . to Directiv tion with pa valve s- und Was lvisory sche é Sanitaire,	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 re 2014/68/EU assport for the serfaches, DV eme WRAS typ	2 3.1) e valve 'GW pe proval		C05 C06 C10 C11 AK1 AK2 AK2 AK3 AK4 AK5	Manufactur Please indic ATEX evalua Certificate o Certification ous oxygen Det Norske Lloyd's Reg American E Bureau Ver Russian Ma type approv	er certificati ate descript ation acc. to of oil- and gr of the produ applications Veritas (DN jister (LR) ty Bureau of SI itas (BV) ty aritime Regi val	ion of certil 2014/34/EL ease free p uction proc by employ NV) type ap ype approv hipping (AE pe approva ster of Shi	ficate: J production ess especially ment of specif oproval al 3S) type appr	oval	



Series 681:

Dimensioning by pressure loss on the outlet pressure side



Flow chart water

Dimensioning by flow velocity

For liquids:

With help of the chart you can determine the nominal diameter (DN) for a given flow volume V (m³/h). According to DVGW-guidelines (DIN 1988) a flow velocity of 2 m/s in domestic water supply systems should not be exceeded.

For compressed air and other gaseous media:

The usual flow velocity for compressed air is 10 - 20 m/s. For gaseous media the flow volume V should always be shown in actual cubic meters/hour. If the flow volume is given in standard cubic meters, these should be converted into actual cubic meters before using the diagram.

 $V(m^{3}/h) = -\frac{V_{\text{Norm}}(Nm^{3}/h)}{p_{\text{absolut}}(bar)} = \frac{V_{\text{Norm}}}{p_{\tilde{v}}+1}$

Actual cubic meters are based on the prevailing pressure of the medium on the outlet side of the pressure reducer.

